

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NORTHEAST WOODFORD)	
WATER DISTRICT FOR A DEVIATION FROM)	
THE REQUIREMENTS OF 807 KAR 5:066,)	CASE NO. 91-026
SECTION 5(4), REGARDING WATER STORAGE)	

O R D E R

By application received January 24, 1991, Northeast Woodford Water District ("Northeast Woodford Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Northeast Woodford Water states in its application that it has employed a consulting engineering firm, which has prepared a plan for the construction and financing of additional water storage facilities to comply with Commission Regulation 807 KAR 5:066, Section 5(4).

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Northeast Woodford Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Northeast Woodford Water should be given until July 1, 1994 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:


1. Northeast Woodford Water be and it hereby is given until July 1, 1994 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Northeast Woodford Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1994.

Done at Frankfort, Kentucky, this 15th day of February, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director